

# VOC Content Test Certificate

Tuesday December 2<sup>nd</sup>, 2008

Manufacturer: CSR Lightweight Systems (Level 1, 9 Help Street, Chatswood NSW 2067)

Sample Description: Cemintel Jointing Compound

Date Tested: November 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia</b>  <b>Green Star Office Design V2 IEQ-13</b>  <b>Green Star Office Interiors V1.1 IEQ-11</b></p>	<p align="center"><b>Cemintel Jointing Compound</b></p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre maximum</p>	<p><b>&lt;10 grams per Litre as VOC content per material</b></p>
<p align="center"><b>Specification</b></p> <p><b>Green Building Council of Australia</b>  <b>Green Star Office Design V3 IEQ-13</b></p>	<p align="center"><b>Cemintel Jointing Compound</b></p>
<p>Dry Wall and Panel Adhesive 50 grams per Litre maximum</p>	<p><b>&lt;10 grams per Litre as VOC content per material</b></p>



Dr. Vyt Garnys  
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ  
 ACA, AIRAH, FMA  
 Managing Director and Principal Consultant

F0811-11