

VOC Content Test Certificate

Tuesday December 2nd, 2008

Manufacturer: CSR Lightweight Systems (Level 1, 9 Help Street, Chatswood NSW 2067)

Sample Description: Cemintel Texture Kalahari Fine

Date Tested: November 2008

Test Method: SCAQMD Method 304-91 Determination of Volatile Organic Compounds (VOC) in Various Materials as referenced by South Coast Air Quality Management Division (SCAQMD) Rule 1168.

Test Data:

| | |
|---|---|
| <p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V2 IEQ-13 Green Star Office Interiors V1.1 IEQ-11</p> | <p align="center">Cemintel Texture Kalahari Fine</p> |
| <p>Architectural Sealant 250 grams per Litre maximum</p> | <p><10 grams per Litre as VOC content per material</p> |
| <p align="center">Specification</p> <p>Green Building Council of Australia Green Star Office Design V3 IEQ-13</p> | <p align="center">Cemintel Texture Kalahari Fine</p> |
| <p>Architectural Sealant 250 grams per Litre maximum</p> | <p><10 grams per Litre as VOC content per material</p> |



Dr. Vyt Garnys
 PhD, BSc(Hons) AIMM, ARACI, ISIAQ
 ACA, AIRAH, FMA
 Managing Director and Principal Consultant

F0811-11