

Certificate Holder:

CSR Building Products
Ltd
Cemintel
Level 5, Trinita 3,
39 Delhi Road
North Ryde NSW 2113
Australia
Tel: + 61 2 9235 8000
www.cemintel.com.au

Certificate number: CM30048 Rev 10

THIS TO CERTIFY THAT

Cemintel Territory Series Cladding System

Type and/or use of product:

Cemintel Territory cavity walling system is an external and internal wall cladding system designed for use with all building types, subject to limitations detailed within this certificate and system / project specific limitations.

Description of product:

Cemintel Territory panels are 455 mm wide, 3,030 mm long and 16 mm nominal thickness. Cemintel Territory panels are available in differing textures and colours. Panels may be installed in horizontal or vertical orientation.

The construction system components are detailed in the technical literature:

- Cemintel Territory Series Design & Installation Guide for External Horizontal Installation
- Cemintel Territory Series Design & Installation Guide for External Vertical Installation
- Cemintel Territory Series Design & Installation Guide for Internal Installation

COMPLIES WITH THE FOLLOWING BCA PROVISIONS AND STATE OR TERRITORY VARIATION(S)

BCA 2022 + A1

| | Volume One | | Volume Two including Housing Provisions | |
|--|-----------------------------------|-----------------------------|---|--|
| Performance Requirement(s) | B1P1 | Structural Provisions | H1P1 | Structural stability and resistance to actions |
| | F3P1 | Damp and Weatherproofing | H2P2 | Weatherproofing |
| Deemed-to-Satisfy Provision(s): | C2D2 & Specification 5 | Fire-Resisting Construction | HP 9.2.3 | Fire Safety – Construction of External Walls |
| | C2D10 (6)(d) | Non-Combustible Material | | |

Scope of certification: The CodeMark Scheme is a building product certification scheme. The rules of the Scheme are available at the ABCB website www.abcb.gov.au. This Certificate of Conformity is to confirm that the relevant requirements of the Building Code of Australia (BCA) as claimed against have been met. The responsibility for the product performance and its fitness for the intended use remain with the certificate holder. The certification is not transferrable to a manufacturer not listed on Appendix A of this certificate.

Disclaimer: The Scheme Owner, Scheme Administrator and Scheme Accreditation Body do not make any representations, warranties or guarantees, and accept no legal liability whatsoever arising from or connected to, the accuracy, reliability, currency or completeness of any material contained within this certificate; and the Scheme Owner, Scheme Administrator and Scheme Accreditation Body disclaim to the extent permitted by law, all liability (including negligence) for claims of losses, expenses, damages and costs arising as a result of the use of the product(s) referred to in this certificate.

The purpose of Global-Mark **construction site audits** is to confirm the practicability of installing the product; and to confirm the appropriateness and accuracy of installation instructions. In placing the **CodeMark mark** on the product/system, the certificate holder makes a declaration of compliance with the certification standard(s) and confirms that the product is identical to the product certified herein. In issuing this Certificate of Approval Global-Mark has relied on the **expertise of external bodies** (laboratories, and technical experts).



Herve Michoux
Global-Mark Managing Director



Peter Gardner
Unrestricted Building Certifier

Date of issue: 28/08/2025

Date of expiry: 01/08/2028

Certificate of Conformity

| | | | | | |
|--|---|--|---|---|--|
| | | C2D11 (1)(b) & Specification 7 | Fire Hazard Properties | | |
| | | F8D3 | Condensation Management | HP 10.8.1 | Condensation Management |
| | | G5D3 | Construction in bushfire prone areas – Protection – Residential Buildings | H7D4 | Construction in bushfire prone areas |
| | | G5D4 | Construction in Bushfire Prone Areas – Protection – Certain Class 9 buildings | | |
| | | J3D8 | External walls of a sole-occupancy unit of a Class 2 building or a Class 4 part of a building | | |
| | | J4D6 | Energy Efficiency – Building Fabric – Walls and Glazing Class 3 & Class 5 to 9 building | HP 13.2.5 | Energy Efficiency - Building Fabric – External Walls |
| | State or territory variation(s): | SA C2D2 (1) | Fire-Resisting Construction | | |
| | | NSW C2D11 | Fire Hazard Properties | | |
| | | VIC C2D11 (3) | Fire Hazard Properties | | |
| | | NSW G5D3 | Construction in Bushfire Prone Areas - Protection | NSW H7D4 | Construction in bushfire prone areas |
| | | NSW G5D4 | Construction in Bushfire Prone Areas – Protection – Class 9 buildings used as a special purpose | | |
| | | VIC G5D4 | Construction in Bushfire Prone Areas – Protection – Certain Class 9 buildings | | |
| | | NSW Section J (NCC 2019 A1 NSW Section J) | Energy Efficiency – Class 2 or Class 4 part of a building (up to V3 BASIX dwellings) | | |
| | | NSW Section J (NCC 2022 Section J) | Energy Efficiency – Class 2 or Class 4 part of a building (V4 or later BASIX dwellings) | | |
| | | NSW Section J (NCC 2019 A1 NSW Section J) | Energy Efficiency – Class 2 or Class 4 part of a building (BASIX Alterations and Additions) | NSW 13.2.5 | Energy Efficiency – External Walls |
| | | NSW Section J (NCC 2022 Section J) | Energy Efficiency – Class 3 or Class 5-9 buildings | NT 13.2.5 | Energy Efficiency Building Fabric – External walls |
| | | TAS Section J (NCC 2019 A1 Section J) | Energy Efficiency – Class 2 or Class 4 part of a building | TAS Part H6 (NCC 2019 A1 Part 2.6) | Energy Efficiency – Building Fabric |

Certificate of Conformity

| SUBJECT TO THE FOLLOWING LIMITATIONS AND CONDITIONS AND THE PRODUCT TECHNICAL DATA IN APPENDIX A AND EVALUATION STATEMENTS IN APPENDIX B | | |
|---|--|--------------------------------------|
| Limitations and conditions: | | Building classification/s: |
| Volume 1 – B1P1 & Volume 2 – H1P1 The wall system as described has maximum design wind load limits documented within the relevant Cemintel Territory Series Design & Installation Guides (refer Appendix B2). When panels are installed in a vertical orientation, the wall system is limited to applications in non-cyclonic regions. For both horizontal and vertical panel orientation, wind load limits, construction detail and fixing must follow the relevant details contained within the engineering detail sections of the relevant Cemintel Territory Series Design & Installation Guides (refer Appendix B2). For time dependent effects, system install is limited to zones C1, C2, C3 & C4 as defined by AS4312:2008 – Atmospheric Corrosivity Zones in Australia. | | Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10 |
| Volume 1 – B1P1 (2)(e), (f) & (i) & Volume 2 – H1P1 (2)(e), (f) & (i) Snow, liquid pressure and earth pressure actions are excluded. | | Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10 |
| Volume 1 – B1P4 & Volume 2 – H1P2 Compliance for flood hazard areas is excluded. | | Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10 |
| Volume 1 – F3P1 & Volume 2 – H2P2 The Cemintel Territory Series remains weatherproof up to Serviceability Limit State (SLS) wind loads of $\pm 3.5\text{kPa}$ with an approved rigid air barrier, or $\pm 1.5\text{kPa}$ when a flexible wall membrane is used as the primary weatherisation barrier, additionally; <ul style="list-style-type: none"> a. windows installed shall comply with AS2047, and b. The wall system shall be designed for Serviceability deflection limits of at least $L/250$ as defined in AS/NZS4284 | | Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10 |
| Volume 1 – F2P2 & SA F2P3 & Volume 2 – H4P1 & SA H4P1 (2) Compliance for use in wet areas is excluded. | | Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10 |
| Volume 1 – C2D2 & Specification 5 & Housing Provisions – 9.2.3 Volume 1 – SA C2D2 (1) Fyrchek MR is required beneath cladding material to achieve external wall FRLs (up to 90/90/90) as outlined in Gyprock The Red Book 1 – Design Guide, April 2025, Section F – External Wall Systems. | | Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10 |
| Volume 1 – C2D10 (1) In a building required to be of Type A or B construction, construction elements and their components must be non-combustible for all external walls, common walls and non-load bearing internal walls that are required to be fire resisting. | | Class 2, 3, 4, 5, 6, 7, 8 & 9 |
| Volume 1 – C2D10 (6)(d) The Cemintel Territory Series Cladding System consists of fibre-reinforced cement sheeting and may be used where non-combustible materials are required. This certification is based upon the system being installed using components & accessories as specified in the Cemintel Territory Series Design & Installation Guides (refer Appendix B2). Substitution of wall system components &/or accessories may be permitted, however the general performance specifications of components &/or accessories must be maintained for this certificate to remain valid. | | Class 2, 3, 4, 5, 6, 7, 8 & 9 |

Certificate of Conformity

| | |
|--|--|
| Volume 1 – C2D10 (6)(f) In external wall applications, flexible sarking membrane (wall wrap) materials shall be installed in accordance with the relevant Cemintel Territory Series Design & Installation Guides (refer Appendix B2) and manufacturer's instructions. | Class 2, 3, 4, 5, 6, 7, 8 & 9 |
| Volume 1 – C2D11 (1)(b) & Specification 7 The Cemintel Territory Series Cladding System may be used where Group 1 materials are required for internal wall linings. | Class 2, 3, 4, 5, 6, 7, 8 & 9 |
| Volume 1 – F8D3 & Housing Provisions – 10.8.1 Pliable building membranes compliant with AS4200.1 shall be installed in accordance with AS4200.2 and the relevant Cemintel Territory Series Design & Installation Guides (refer Appendix B2). Compliance with this clause maintains compliance with Volume 1 – F3P1 & Volume 2 – H2P2, plus Volume 1 – G5D3, G5D4 & Volume 2 – H7D4. | Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10 |
| Volume 1 – G5D3 & Volume 2 – H7D4 In designated bushfire prone areas, when the building is constructed in accordance with: <ul style="list-style-type: none"> AS3959:2018 including Amendment 1 & 2, or NASH Standard – Steel Framed Construction in Bushfire Areas (where applicable), Cemintel Territory Series Cladding System is permitted for use as external wall cladding in buildings subject to Bushfire Attack Level not exceeding BAL-40. | Class 1, 2, 3 buildings & Class 10a building or deck immediately adjacent or connected to building Class 1, 2 or 3 |
| Volume 1 – G5D4 In designated bushfire prone areas, when the building is constructed in accordance with Specification 43, Cemintel Territory Series Cladding System is permitted for use as external wall cladding only in buildings subject to Bushfire Attack Level not exceeding BAL-12.5. Construction in BAL-19, BAL-29, BAL-40 and BAL-FZ are outside the scope of application of the clause. | Class 9a, 9b, 9c buildings and Class 10a building or deck immediately adjacent or connected to a Class 9a, 9b or 9c building |
| Volume 1 – J3D8 & J4D6 & Housing Provisions – 13.2.5 Volume 1 – NSW J3D8 & NSW J4D6 & Housing Provisions – NSW 13.2.5 & NT 13.2.5 The wall system contributes towards the Total wall system U or R value, determined in accordance with Volume 1 – J3D8, J4D6, NSW J3D8, NSW J4D6 or Housing Provisions – 13.2.5, NSW 13.2.5 or NT 13.2.5. Insulation shall be included within the wall system, as outlined in the Cemintel Territory Series Design & Installation Guides (refer Appendix B2). | Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10 |
| Volume 1 – NSW G5D3 & Volume 2 – NSW H7D4 In designated bushfire prone areas subject to all Bushfire Attack Levels up to and including BAL-29, determined in accordance with Planning for Bush Fire Protection 2019 including addendum November 2022, when the building is constructed in accordance with: <ul style="list-style-type: none"> AS3959: 2018 including Amendments 1 & 2, or NASH Standard – Steel Framed Construction in Bushfire Areas (where applicable), except as modified by Planning for Bush Fire Protection 2019 including addendum November 2022, Cemintel Territory Series Cladding System is permitted for use as external wall cladding. The compliance assessment of the certified system is limited to sections 7.5 and 8.3.2 of Planning for Bush Fire Protection 2019 including addendum November 2022. | Class 1, 2, 3 buildings, Class 4 part of a building & Class 10a building or deck immediately adjacent or connected to building Class 1, 2, 3 or Class 4 part of a building |

Certificate of Conformity

| | | |
|--|--|---|
| | <p>Site specific conditions have not been considered for this compliance assessment, these may include:</p> <ul style="list-style-type: none"> the development consent following consultation with the NSW Rural Fire Service under section 4.14 of the Environmental Planning and Assessment Act 1979 if required, or the development consent with a bushfire safety authority issued under section 100B of the Rural Fires Act 1997 for the purposes of integrated development <p>Planning for Bush Fire Protection 2019 including addendum November 2022 requires a performance-based application in bushfire prone areas subject to Bushfire Attack BAL-40 and BAL-FZ.</p> <p>Construction within NSW's bushfire prone areas subject to Bushfire Attack BAL-40 and BAL-FZ have not been considered in this assessment.</p> | |
| | <p>Volume 1 – NSW G5D4</p> <p>In designated bushfire prone areas Cemintel Territory Series Cladding System is permitted for use as external wall cladding in buildings subject to a Bushfire Attack Level (BAL) not exceeding BAL-12.5, determined in accordance with Planning for Bush Fire Protection 2019 including addendum November 2022, when the building is constructed in accordance with:</p> <ol style="list-style-type: none"> For Class 9 building, Specification 43, except as modified by Planning for Bush Fire Protection 2019 including addendum November 2022, or For Class 10a building or deck AS3959: 2018 including Amendment 1 & 2 except as modified by Planning for Bush Fire Protection 2019 including addendum November 2022, and S43C13 <p>The compliance assessment of the certified system is limited to sections 7.5 and 8.3.2 of Planning for Bush Fire Protection 2019 including addendum November 2022.</p> <p>Site specific conditions arising from development consent with a bushfire safety authority issued under section 100B of the Rural Fires Act 1997 for the purposes of integrated development have not been considered for the compliance assessment.</p> <p>Construction within NSW in BAL-19, BAL-29, BAL-40 and BAL-FZ are outside the scope of application of the clause.</p> | <p>Class 9 building that is a special fire protection purpose; and a Class 10a building or deck immediately adjacent or connected to such a building</p> |
| | <p>Volume 1 – VIC G5D4</p> <p>In designated bushfire prone areas, when the building is constructed in accordance with Specification 43, Cemintel Territory Series Cladding System is permitted for use as external wall cladding in buildings subject to Bushfire Attack Level not exceeding BAL-12.5.</p> <p>Construction within VIC in BAL-19, BAL-29, BAL-40 and BAL-FZ are outside the scope of application of the clause.</p> | <p>Class 9a, 9b, 9c buildings, Class 4 part of a building and Class 10a building or deck immediately adjacent or connected to Class 9a, 9b or 9c building or Class 4 part of a building</p> |
| | <p>General</p> <p>Compliance, where panels are exposed to temperature over 50° C, is excluded, for example around chimneys and fireplaces.</p> | <p>Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10</p> |
| | <p>General</p> <p>The supporting structures including stud frame & internal linings shall be in accordance with the relevant Australian Standard and/or designed & specified by a suitably qualified design professional, and installed by suitably qualified and trained building professionals, in accordance with manufacturer guidelines and the relevant Cemintel Territory Series Cladding System Design and Installation Guides (refer Appendix B2).</p> | <p>Class 1, 2, 3, 4, 5, 6, 7, 8, 9 & 10</p> |

APPENDIX A – PRODUCT TECHNICAL DATA

A1 Type and intended use of product

Cemintel Territory Series is an external and internal wall cladding system designed for use with all building types. Refer details on page 1.

A2 Description of product

Refer details on Page 1. The Cemintel Territory products listed below and the related accessories are no longer sold by Cemintel, but are covered by this CodeMark Certificate:

| Material Code | Product Description | Material Code | Product Description |
|---------------|--|---------------|--|
| 133935 | Territory Savanna Cloud Panel – 16mm x 455mm x 3030mm | 472360 | Territory Woodlands Jarrah Slats Panel – 16mm x 455mm x 3030mm |
| 133937 | Territory Savanna Mist Panel – 16mm x 455mm x 3030mm | 472362 | Territory Woodlands Oak Slats Panel – 16mm x 455mm x 3030mm |
| 133938 | Territory Savanna Shade Panel – 16mm x 455mm x 3030mm | 472363 | Territory Canyon Carnarvon Panel – 16mm x 455mm x 3030mm |
| 477863 | Territory Savanna Shadow Panel – 16mm x 455mm x 3030mm | 472365 | Territory Canyon King Panel – 16mm x 455mm x 3030mm |
| - | - | 472377 | Territory Woodlands Cedar Panel – 16mm x 455mm x 3030mm |

A3 Product specification

Refer to items 1, 2 & 3 listed in Appendix B2:

- Cemintel Design and Installation Guide – Territory™ Series – External Horizontal Installation, dated 08/2025
- Cemintel Design and Installation Guide – Territory™ Series – External Vertical Installation, dated 08/2025
- Cemintel Design and Installation Guide – Territory™ Series – Internal Walls, dated 08/2025

A4 Manufacturer and manufacturing plant(s)

| | |
|-------------------------|-------------------------|
| CSR Cemintel | Nichiha Corporation |
| 376 Victoria Street | 2-18-19 Nishiki, Nakaku |
| Wetherill Park NSW 2164 | Nagoya 460-8610, Japan |

A5 Installation requirements

Refer to items 1, 2, 3 & 4 listed in Appendix B2:

- Cemintel Design and Installation Guide – Territory™ Series – External Horizontal Installation, dated 08/2025
- Cemintel Design and Installation Guide – Territory™ Series – External Vertical Installation, dated 08/2025
- Cemintel Design and Installation Guide – Territory™ Series – Internal Walls, dated 08/2025
- Cemintel Product Guide For BushFire-Prone Areas, November 2023

A6 Other relevant technical data

Refer to items 1, 2 & 3 listed in Appendix B2:

- Cemintel Design and Installation Guide – Territory™ Series – External Horizontal Installation, dated 08/2025
- Cemintel Design and Installation Guide – Territory™ Series – External Vertical Installation, dated 08/2025
- Cemintel Design and Installation Guide – Territory™ Series – Internal Walls, dated 08/2025
- Gyprock The Red Book 1 – Design Guide, April 2025, Section F – External Wall Systems

Plus any referenced documents within the technical literature identified in Appendix B2.

APPENDIX B – EVALUATION STATEMENTS

B1 Evaluation methods

The following assessment methods have been used to determine compliance with BCA 2022 (+A1):

| Code Clause | Assessment Method(s) | Evidence of suitability | Evidence reference in B2 |
|--|----------------------------|---|---|
| BCA Volume One – B1P1 | A2G2 – 2 (a) & (c) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 3, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15 & 16 |
| BCA Volume Two – H1P1 | A2G2 – 2 (a) & (c) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 3, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15 & 16 |
| BCA Volume One – F3P1 | A2G2 – 2 (a), (b)(i) & (c) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 16, 24, 25, 26, 27 & 28 |
| BCA Volume Two – H2P2 | A2G2 – 2 (a), (b)(i) & (c) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 16, 24, 25, 26, 27 & 28 |
| BCA Volume One – C2D2 & Specification 5 | A2G3 – 2 (a) & (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 5, 17, 18, 19, 20, 21, 22 & 23 |
| ABCB Housing Provisions – 9.2.3 | A2G3 – 2 (a) & (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – C2D10 | A2G3 – 2 (a) & (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – C2D11 & Specification 7 | A2G3 – 2 (a) & (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – F8D3 | A2G3 – 2 (a) & (b) | A5G3 – 1 (f) – Other documentary evidence | Items 1 & 2 |
| ABCB Housing Provisions – 10.8.1 | A2G3 – 2 (a) & (b) | A5G3 – 1 (f) – Other documentary evidence | Items 1 & 2 |
| BCA Volume One – G5D3 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 4, 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume Two – H7D4 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 4, 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – G5D4 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 4, 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – J3D8 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |
| BCA Volume One – J4D6 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |
| ABCB Housing Provisions – 13.2.5 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |
| BCA Volume One – SA C2D2 (1) | A2G3 – 2 (a) & (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – NSW C2D11 | A2G3 – 2 (a) & (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – VIC C2D11 (3) | A2G3 – 2 (a) & (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – NSW G5D3 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 4, 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume Two – NSW H7D4 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 4, 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – NSW G5D4 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 4, 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – VIC G5D4 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 4, 5, 17, 18, 19, 20, 21, 22 & 23 |
| BCA Volume One – NSW Section J (NCC 2019 A1 NSW Section J) up to V3 BASIX | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |
| BCA Volume One – NSW Section J (NCC 2022 Section J) V4 BASIX and later | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |
| BCA Volume One – NSW Section J (NCC 2019 A1 NSW Section J) BASIX Alterations | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |
| ABCB Housing Provisions – NSW 13.2.5 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |

Certificate of Conformity

| Code Clause | Assessment Method(s) | Evidence of suitability | Evidence reference in B2 |
|--|----------------------|---|------------------------------------|
| BCA Volume One – NSW Section J (NCC 2022 Section J) Class 3 & Class 5 to 9 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |
| ABCB Housing Provisions – NT 13.2.5 | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |
| BCA Volume One – TAS Section J (NCC 2019 A1 Section J) | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |
| BCA Volume Two – TAS H6 (NCC 2019 A1 Part 2.6) | A2G3 – 2 (a)& (b) | A5G3 – 1 (d) & (e) – Test report & expert judgement | Items 1, 2, 5, 29, 30, 31, 32 & 33 |

B2 Reports

The following reports have been used as evidence to determine compliance with BCA 2022 (+A1):

| Ref | Author | Reference | Date | Description | NATA Registration |
|-----|--------------------------|---|-------------|--|-------------------|
| 1. | CSR Cemintel | Territory Series – External Horizontal Installation | Aug 2025 | Territory Series D&I Guide External Horizontal install | - |
| 2. | CSR Cemintel | Territory Series – External Vertical Installation | Aug 2025 | Territory Series D&I Guide External Vertical install | - |
| 3. | CSR Cemintel | Territory Series – Internal Installation | Aug 2025 | Territory Series D&I Guide Internal Walls | - |
| 4. | CSR Cemintel | Product Guide For BushFire-Prone Areas | Nov 2023 | Cemintel Construction Guide For Bush Fire Areas | - |
| 5. | CSR Gyprock | The Red Book 1 – Design Guide | Apr 2025 | The Red Book Design Guide | - |
| 6. | David Beneke Consulting | 2012-32-LO-216 | 19 Oct 2023 | Structural engineering certificate | - |
| 7. | David Beneke Consulting | 2012-32-LO-217 | 19 Oct 2023 | Structural engineering certificate | - |
| 8. | David Beneke Consulting | 2012-32-LO-218 | 19 Oct 2023 | Structural engineering certificate | - |
| 9. | David Beneke Consulting | 2012-32-LO-265 | 7 May 2024 | Structural engineering certificate | - |
| 10. | James Cook Uni | TS1044 | 25 Aug 2016 | Structural test report | 14937 |
| 11. | James Cook Uni | TS1044 Review Letter | 14 Aug 2025 | Structural test compliance statement | 14937 |
| 12. | Ian Bennie & Assoc | 2016-066-S2 | 8 Nov 2016 | Structural Test report | 2371 |
| 13. | Ian Bennie & Assoc | 2016-066-S3 | 8 Nov 2016 | Structural Test report | 2371 |
| 14. | Quasar | B13090901-1 | 27 Sep 2013 | Durability analysis report | - |
| 15. | The Coatings Consultancy | TCC24107 | 16 May 2025 | Durability assessment report | - |
| 16. | Venn Engineering | VE-CSR230210A | 8 Feb 2024 | Structural & Weatherproofing Assessment | - |
| 17. | CSIRO | FNK10457 | 21 Mar 2012 | Fire Test report & certificate | 165 |
| 18. | Jensen Hughes | WF45759 – FAS190252 R14.2 | 18 Aug 2025 | Fire Assessment report | 3277 |
| 19. | BRANZ | FC12969-01-05 | 8 May 2025 | Fire Assessment report | IANZ 37 |
| 20. | BRANZ | FC12946-01-13 | 6 May 2025 | Fire Assessment report | IANZ 37 |
| 21. | SGA | 2013/277.3 R1.2 | 7 Feb 2020 | Fire Compliance Assessment report | - |
| 22. | Warringtonfire | RTF180305a2 | 8 Jul 2019 | Fire Test report | 3277 |
| 23. | Warringtonfire | ASCRRTF180305 R2 | 8 Jul 2019 | Fire Classification report | 3277 |
| 24. | Ian Bennie & Assoc | 2016-066-S1 | 21 Nov 2016 | Weather proofing Test report | 2371 |
| 25. | Xavier Knight | 220912 R03 | 1 Aug 2025 | Weather proofing Assessment report | - |
| 26. | BRANZ | DC2314-DU01 | 15 Nov 2012 | Weather proofing Test report | IANZ 918 |

Certificate of Conformity

| Ref | Author | Reference | Date | Description | NATA Registration |
|-----|------------------------------------|-------------------------------|-------------|------------------------------|-------------------|
| 27. | BRANZ | DC2568 | 6 May 2015 | Weather proofing Test report | IANZ 918 |
| 28. | CSIRO | DTF1045 | 16 Feb 2016 | Weather proofing Test report | 165 |
| 29. | CSR Insulation Research Laboratory | TC906 R-13003 Designer Series | 13 Mar 2013 | Thermal Test report | 993 |
| 30. | LittleShrub Pty Ltd | CSRRB2-08.03 | 3 Aug 2023 | Thermal Calculation report | - |
| 31. | LittleShrub Pty Ltd | CSRRB2-09.03 | 3 Aug 2023 | Thermal Calculation report | - |
| 32. | LittleShrub Pty Ltd | CSRRB2-10.03 | 3 Aug 2023 | Thermal Calculation report | - |
| 33. | LittleShrub Pty Ltd | CSRRB2-11.03 | 3 Aug 2023 | Thermal Calculation report | - |

The Certificate Holder has chosen not to make the above identified evidence of compliance publicly available, due to the documents being considered commercial in confidence.

End of Certificate.